



**THE CITY OF SAN DIEGO
DEVELOPMENT SERVICES DEPARTMENT**

Date Of Notice: **July 12, 2002**

**PUBLIC NOTICE OF A
PROPOSED NEGATIVE DECLARATION
Job Order Number 176811**

A draft Negative Declaration has been prepared by the City of San Diego Land Development Review Division for the project listed below. Written comments regarding the adequacy of this Draft Negative Declaration must be received by the Land Development Review Division at the address below by **August 10, 2002**. A final environmental report incorporating public input will then be prepared for consideration by decision-making authorities.

SUBJECT: **Sewer Pump Station Rehabilitation:** CITY COUNCIL APPROVAL to conduct mechanical, electrical, and ventilation system upgrades to existing sewer pump stations 25, 31, 32, 33, and 40. Electrical upgrades at Station 25 would require approximately 2,000 linear feet of new trenching approximately one to three feet deep to run new electrical conduit. Upgrades at Stations 25, 31, and 40 would include new or upgraded ventilation systems to continuously vent hydrogen sulfide gas. Station 40 include replacement and upgrade of the emergency back-up generator. Applicant: City of San Diego Engineering and Capital Projects Department, Wastewater Facilities Division.

LDR No. 42-0417 (PTS 4012)

COMMUNITY PLAN AREAS: La Jolla, Otay Mesa, and Midway.

COUNCIL DISTRICTS: 2 (Wear), 8 (Inzunza).

This recommended finding that the project will not have a significant effect on the environment is based on the draft Negative Declaration and an Environmental Initial Study conducted by the City. The draft Negative Declaration, Initial Study, and supporting documents may be reviewed, or purchased for the cost of reproduction, at the office of the Land Development Review Division, 1222 First Avenue, Fifth Floor, San Diego, CA 92101.

To request the draft Negative Declaration, Initial Study, and/or supporting documents in alternative format, call the Development Services Department at (619) 446-5460 immediately to ensure availability. This information is also available in alternative formats for persons with disabilities. To request this notice in alternative format, call (619) 446-5446 or (800) 735-2929 (TEXT TELEPHONE). For environmental review information, contact Cory Wilkinson at (619) 446-5182. This notice was/will be published in the SAN DIEGO DAILY TRANSCRIPT and distributed on **July 12, 2002**.

Lawrence C. Monserrate, Environmental Review Manager
Development Services Department